

Simatic PDM V8.x / V9.x integration

The following steps must be completed to integrate a Wandfluh AG HART EDD file into Simatic PDM V8.x / V9.x.

Simatic configuration files

- Edit the following file:
C:\ProgramData\Siemens\Automation\SIMATIC_PDM\EDD_WorkingDir\edd_catalog\catalogdata\manufacturer.csv
- Add the following line to the end of the file:
Wandfluh AG; ; ; ; WANDFLUH; 0x6103;
- Edit the following file:
C:\ProgramData\Siemens\Automation\SIMATIC_PDM\EDD_WorkingDir\edd_catalog\DEVICE\SI__DEV01.cfg
- Add the following lines to the end of the file:
MANUFACTURER 0x6103 = WANDFLUH
DEVICE_TYPE 0xE3F0 = _SD733
DEVICE_TYPE 0xE3F1 = _SD736

Integrate the EDD file

- Open the Device integration Manager
- In the menu select “File”→”Read device description from compressed source...”.
- Select the EDD zip file
- Set a checkmark at Devices→Actuators→Hydraulic→Wandfluh AG→SD73x
- In the menu select “Catalog”→”Integration”
- The EDD file is now integrated and can be assigned to devices in Simatic PDM